



Textilní zkušební ústav

**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)  
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS  
VÁCLAVSKÁ 6, 658 41 BRNO, CZECH REPUBLIC

issues

to the producer: **FATRA, a.s., třída Tomáše Bati 1541, 763 61 Napajedla, Czech Republic**  
IN: 27465021

## **TESTIMONIAL**

**No.: 12 - 246**

this testimonial confirms these the products:

**heterogeneous vinyl floor coverings DUAL,  
NOVOFLOR STANDARD, NOVOFLOR EXTRA**

material composition: polyvinylchloride

complies with the requirements of standard:

- **EN ISO 846 Plastics – Evaluation of the action of microorganism  
(method C: Resistance to bacteria – visual evaluation)**

On the tested sample (representative DUAL) was visually determined no growth of the bacteria. The test was carried out with bacteria *Pseudomonas aeruginosa*. The sample did not make source of nourishment and it was not decomposed by the test bacteria. On the tested samples was determined no visual changes.

It has been ascertained on the base of microbiological test that assessed product is resistant to activity of bacteria.

This testimonial has been issued on the basis of the application No. COV/12/261 dated 09.11.2012. The base for this testimonial is the test protocol No. CHZ 12/0760 dated 18.12.2012, issued by the accredited test laboratory of TZÚ Brno.

Testimonial was issued: Brno, 20.12.2012

Issued by:

Validity up to: 31.12.2014



  
Jitka Paulová  
Certification Body